


Warm Air Machine Dtat Sheet					Author	Check	APP.
					Welp		JA
Model Name	CAH-T1620A	Date	2022. 12. 20	Checker	Kim Tae Kap		
Combus tibility	Standard value			Measure Value			
	CO2	%	10~13%	11.70%			
	CO	PPM	100PPM below	0 ppm			
	O2	%	↑ 5% Over then	9.00%			
Remarks	 <p> Fuel Natural gas  CO2max 11.7%  9.0% O2  0ppm CO  274.1°C Fluegas Temp  77.1% EFF  ---.---ppm Ambient CO  14.1°C Ambient Temp  ---.---hPa Draft  69.7% Excess air  ---.---hPa Pressure  6.56% CO2  3ppm Undiluted CO  Smoke no. ---  Smoke no. 0 ---  HCT _____°C </p>						