


Warm Air Machine Dtat Sheet					Author	Check	APP.
Model Name	CAH-T1320A	Date	2022. 12. 20	Checker	<i>Kim Tae Kap</i>		
Combus tibility	Standard value			Measure Value			
	CO2	%	10~13%	11.70%			
	CO	PPM	100PPM below	10 ppm			
	O2	%	↑ 5% Over then	7.50%			
Remarks	 <p>Fuel Natural gas CO2max 11.7%</p> <p>7.5% O2 10ppm CO 407.8°C Fluegas Temp 72.1% EFF — ppm Ambient CO 4.4°C Ambient Temp — hPa Draft 43.6% Excess air — hPa Pressure 7.51% CO2 11ppm Undiluted CO</p> <p>Smoke no. — — — Smoke no. 0 — HCT — °C</p>						