




Warm Air Machine Dtat Sheet					Author	Check	APP.
							
Model Name	CAH-T0820A	Date	2022. 12. 20	Checker			
Combus tibility	Standard value			Measure Value			
	CO2	%	10~13%	11.70%			
	CO	PPM	100PPM below	3 ppm			
	O2	%	↑ 5% Over then	7.70%			
Remarks	