


Warm Air Machine Dtat Sheet					Author	Check	APP.
					Wahp		JK
Model Name	CAH-T2120A	Date	2022. 12. 20	Checker	Kim Tae Kap		
Combus tibility	Standard value			Measure Value			
	CO2	%	10~13%	11.70%			
	CO	PPM	100PPM below	0 ppm			
	O2	%	↑ 5% Over then	8.70%			
Remarks	 <p>           Fuel            CO2max            8.7%            O2            0ppm            279.1°C            76.9%            --- ppm            4.1°C            --- hPa            64.5%            --- hPa            6.79%            0ppm            Smoke no. ---            Smoke no. 0 ---            HCT _____°C         </p> <p>           Natural gas            11.7%            CO            Fluegas Temp            EFF            Ambient CO            Ambient Temp            Draft            Excess air            Pressure            CO2            Undiluted CO         </p>						