

# Warm Air Machine Dtat Sheet

Author

Check

APP.

*Welp*

*JA*

Model Name

CAH-T0720A

2022. 12. 20

Checker

*Kim Joe Kap*

Combus tibility	Standard value			Measure Value
	CO2	%	10~13%	11.70%
	CO	PPM	100PPM below	1 ppm
	O2	%	↑ 5% Over then	7.70%

Remarks

Fuel Natural gas  
CO2max 11.7%

7.7% O2  
1ppm CO  
394.0°C Fluegas Temp  
74.3% EFF  
--- ppm Ambient CO  
43.6°C Ambient Temp  
--- hPa Draft  
52.8% Excess air  
--- hPa Pressure  
7.34% CO2  
1ppm Undiluted CO

Smoke no. ---  
Smoke no. Ø ---  
HCT \_\_\_\_\_ °C

For questions call---