

# Warm Air Machine Dtat Sheet

Author

Check

APP.

*Welp*

*JK*

Model Name

CAH-T1120A

Date

2022. 12. 20

Checker

*Kim Tae Kap*

Combus tibility	Standard value			Measure Value
	CO2	%	10~13%	11.70%
	CO	PPM	100PPM below	0 ppm
	O2	%	↑ 5% Over then	9.00%

Remarks

Fuel	Natural gas
CO2max	11.7%
9.0%	O2
0ppm	CO
400.8°C	Fluegas Temp
72.7%	EFF
--- ppm	Ambient CO
43.6°C	Ambient Temp
--- hPa	Draft
67.0%	Excess air
--- hPa	Pressure
6.67%	CO2
0ppm	Undiluted CO
Smoke no.	---
Smoke no. 0	-
HCT	_____°C